

Double click here to insert your company header

Maximum logo Dimensions - 5.45cm x 18.5 cm
747 x 164 pixels



Click Toggle Logo button in the Add-ins ribbon to remove this header

EMERGENCY LIGHTING PERIODIC INSPECTION AND TESTING CERTIFICATE

CLIENT DETAILS

Name and
Address

Postcode

INSTALLATION DETAILS

Address

Postcode

Extent of system
covered by this
Certificate

CERTIFICATION

Contractor responsible for carrying out the
inspection and testing – (Trading title)

Address:

Telephone Number:

Postcode:

I/We hereby certify that the emergency lighting system installation at the above premises has been inspected and tested by me/us in accordance with the "Results Schedule of items inspected and tested" on page 2, and to the best of my/our knowledge and belief, the installation complies at the time of my/our inspection and testing with the recommendations given in BS 5266-1: 2025 Emergency lighting Part 1: Code of practice for the emergency lighting of premises, BS EN 50172: 2024 Emergency escape lighting systems – , except as stated below.

For the inspection and testing of the installation:

Name
(Capitals)

Signature

Inspector

Date

DETAILS OF DEPARTURES FROM THE CURRENT STANDARDS

Requirement Number

Details of deviations (Additional space to continue list is provided on page 3)

RELATED REFERENCE DOCUMENTS

Electrical Installation Condition Report No. and/or
date * (most recent- covering the existing emergency
lighting installation – see Note 1)

Other documents (if any) please state

NEXT INSPECTION

Enter interval in accordance with Clause 7.2 of BS EN 50172: 2024

I/We recommend that this installation is further inspected and tested after an interval of not more than:

Note: 1. The wiring system of an existing emergency lighting system should have been periodically inspected and tested in accordance with BS 7671:2018 + A3:2024 and an Electrical Installation Condition Report issued. Where applicable and where available, the serial number and/or the date of the most recent report should be recorded in the related reference document section.

SCHEDULE OF ITEMS INSPECTED AND TESTED

Certificate Reference:

ELPI

PURPOSE OF INSTALLED EMERGENCY LIGHTING SYSTEM

Tick applicable box(es)

Emergency escape lighting	Standby lighting
Escape route lighting	Partial standby lighting
Open area lighting	High risk task area lighting

EMERGENCY LIGHTING INSTALLATION DETAILS

Tick applicable box(es)

Self-contained emergency luminaire	Combined emergency luminaire
Central battery system	Standby generator system

CATEGORIES OF OPERATION FOR EMERGENCY LIGHTING SYSTEM

Type	Mode	Facilities	Duration

RESULTS OF INSPECTION AND TESTING

BS 5266- 1:2025 clause reference	Requirements	* If 'No' record the deviation on page 1.	System Conforms (indicate with ✓) Yes No * N/A
4.2	P1- Plans are available and correct		
Clause 5	P2- Under test conditions, adequate ** illumination provided for safe movement on the escape route and open areas.		
6.6	P3- Luminaires correctly positioned and oriented as shown on the plans		
Clause 10	P4- Original design still valid		
5.4	P5- All escape route safety signs and fire fighting equipment location signs visible with the normal lighting extinguished		
6.6	P6- Correct application and siting of additional emergency lighting		
6.7	P7- Luminaires conform to BS EN 60598-2-22		
6.7	P8- Luminaires have an appropriate Ingress Protection rating for their location, as specified in the system design.		
Clause 8	P9- Wiring systems comply with the requirements of BS 7671:2018 + A3:2024		
8.2	P10- Fire protection of central wiring systems satisfactory (including cable supports)		
8.2.6	P11- Emergency lighting circuits correctly segregated from other supplies		
8.2.12	P12- Wiring to emergency lighting power supply sources a fixed installation, where a specialist plug and socket arrangement is used, it is protected against unauthorised interference		
8.3.3	P13- System has a suitable test facility for the application		
8.3.5	P14- Central power system output voltage range is compatible with the supply voltage range of the luminaires, taking into account supply cable voltage drop		
12.3	P15- Luminaires tested and found to operate for their full rated duration		
10.6	P16- Instructions for operations and maintenance		
Clause 11	P17- Test results in the logbook complete and satisfactory		
10.6; 10.7	P18- Instructions together with a suitable logbook showing a satisfactory commissioning test available for use by the building occupier		
Clause 12	P19- Luminaires clean and undamaged with lamps in good condition		
10.7	P20- Building occupier and their staff trained on suitable maintenance, testing and operating procedures, or a current maintenance contract is in place.		
Clause 12	P21- Evidence of servicing of Central Battery System (in line with manufacturer's procedures); in-house or current maintenance contract is in place.		
12.2	P22- Evidence of servicing of Standby Generator System (in line with manufacturer's procedures); in-house or current maintenance contract is in place.		
12.3	P23- After test the charging indicators operate correctly.		

** This can be checked by visual inspection and checking that the illumination from the luminaires is not obscured and that minimum design spacings have been met

TEST INSTRUMENTS USED

Where periodic requirement P2 is carried out by measurement, details of instruments MUST be recorded.

Instrument 1 (light meter) Model	Serial Number	Instrument 2 (if any) Model	Serial Number

Notes: Important: all tests should be undertaken at times of minimum risk. If necessary, temporary emergency lighting should be installed until the emergency lighting batteries have been recharged.

COMMENTS ON INSTALLATION AND ADDITIONAL DETAILS OF DETAILS OF DEVIATIONS FROM THE STANDARDS

Certificate Reference:

ELPI

COMMENTS (IF ANY)

DETAILS OF DEVIATIONS FROM THE STANDARDS

(Continued from Page 1)

INFORMATION ON ALTERNATIVE METHOD USED TO VERIFY ILLUMINATION REQUIREMENT P2